

**BEFORE THE NATIONAL GREEN TRIBUNAL  
PRINCIPAL BENCH, NEW DELHI**

**Original Application No. 124 of 2015**

**Sumitra Devi Vs. CPCB & Ors.**

**CORAM :** HON'BLE MR. JUSTICE SWATANTER KUMAR, CHAIRPERSON  
HON'BLE MR. JUSTICE M.S. NAMBIAR, JUDICIAL MEMBER  
HON'BLE DR. D.K. AGRAWAL, EXPERT MEMBER  
HON'BLE MR. BIKRAM SINGH SAJWAN, EXPERT MEMBER  
HON'BLE Mr. RANJAN CHATTERJEE, EXPERT MEMBER

**Present:**

<b>Applicant:</b>	Mr. Saurabh Sharma, Adv.
<b>Respondent No. 1:</b>	Mr. Raj Kumar, Adv. with MrBhupender Kumar and Mr. Nitin Choudhary, (L.A.) CPCB
<b>Respondent No. 5:</b>	Mr. S.S. Shamsbery, AAG with Preeti Bhardwaj, Adv.
<b>Respondent No. 4:</b>	Mr. Amit Lubhaya, Adv.
<b>Respondent No. 6 to 8:</b>	Mr. Anil Grover, AAG and Mr. Rahul Khurana, Adv.
<b>State of Rajasthan:</b>	Mr. Shiv Mangal Sharma, AAG and Mr. Saurabh Rajpal, Adv.
<b>RSPCB:</b>	Mr. Lokendra Kachawa and Mr. Shiv Mangal Sharma, Adv. Mr. Vijay Singhal, Chief Environemal Engineer, Rajasthan SPCB

	<b>Date and Remarks</b>	<b>Orders of the Tribunal</b>
	<b>Item No. 10</b> <b>November 19, 2015</b>	<p>We direct that the Secretary Environment, Urban Development of both the States i.e. State of Rajasthan and State of Haryana, to hold a meeting and submit the report to the Tribunal in relation to why effluent is being discharged on the land of Haryana, thus causing pollution of groundwater as well as health hazards. They should examine why not the State of Haryana put up a CETP at the mouth of the drains and ensure that release of trade effluent from CETP is as per the prescribed standards and it is recycled for Agriculture and Horticulture and even for industrial purpose. More than 11 industrial clusters are stated to be located in Bhiwadi and around. It should also be examined as to why extraction of groundwater should be for industrial purpose. Dr. Vijai Singhal, Chief Environmental Engineer, Rajasthan State Pollution Control Board has stated that total discharge of industrial</p>

effluent of these 11 industrial clusters are 15 to 20 MLD, however, the Officer is not certain about it. The 11 industrial clusters also release 4 MLD of sewage, however, the Officer cannot inform us what is the sewage discharge of Bhiwadi and the surrounding areas. STP of 4 MLD capacity has been installed and another CETP of 6 MLD has been installed. Neither CETP nor STP is discharging treated effluent as per the prescribed parameters.

Let the report be submitted before the Tribunal positively before the next date of hearing.

List this matter on 16<sup>th</sup> December, 2015.

.....,CP  
(Swatanter Kumar)

.....,JM  
(M.S. Nambiar)

.....,EM  
(Dr. D.K. Agrawal)

.....,EM  
(B.S. Sajwan)

.....,EM  
(Ranjan Chatterjee)

